

**TEST REPORT**

ULR No. TC 4367 22 0 00001139-3-1P

TC Date : 12.07.2022

Date of Received: 01.07.2022

Date of Start Testing : 02.07.2022

Date of completion: 12.07.2022

Page No.: 1 of 1

**Testing of Silica cloth (fire isolator)**

Sample Description: Silica cloth( fire isolator)

Size: 500mm x 500mm

**Test Specification: EN 13501-1**

Sr No.	Test Parameters	Test Method	Observation
1	Non-combustibility	ISO 1182 : 2020	Passes the test (Classes A1, A2, A1f, A2f, A1L and A2L)
2	Heat of combustion	ISO 1716 : 2018	Passes the test (Classes A1, A2, A1f, A2f, A1L and A2L)
3	Single burning item	ISO 13823 : 2008	Passes the test (Classes A2, A2L, B, BL, C, CL, D and DL)

~ End of Report ~

Checked by:



For HPL Engineering Services

Authorised Signatory

**Note**

● Sample not drawn by HPL Engineering Services and analysis conducted on "as received basis", unless specified otherwise ● The result relate only to the sample tested ● Endorsement of Product is neither inferred nor implied. The Certificate shall not to be reproduced wholly or in parts and cannot be used as evidence in a Court of Law ● Total liability of the laboratory is limited to the invoiced amount ● Any complaints regarding test report shall inform in writing within 7 days from issue of reports ● After the period it will be assumed that the Test Report is acceptable for the customer.

**"NABL" Approved Laboratory as per ISO/IEC 17025 : 2017****HPL/QF/7.8/01**